

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. AEE/PHE/DIA/JTM-05/2024-25/1203Dated: 13/05/2024

It is certified that an inspection team headed by Akrubajyoti Borothakur, AEE,
PHE, Digboi Sub-Division (Name of Officers with designation) from
Public Health Engineering Dept. (Name of Department/ Office)
 inspected the OIL VALLEY SCHOOL, BOGAPANI COLONY,
DIABOI, ASSAM-786171 (Name & Address of the school)
 on 10-05-2024 (date of inspection), checked the water test report submitted by the school and
 found that the school has potable drinking water for students and staff of the institution and is having
 provision for running water in the toilets and maintaining hygienic sanitation condition in the school
 building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 YEAR (ONE YEAR)

[Signature]
 Asstt. Executive Engineer (PHE)
 Digboi Sub-Division
 Digboi

Signature with Seal:

Name : Akrubajyoti BorothakurDesignation : Assistant Executive Engineer

Assistant Engineer of

the Govt. Public Health Department (PHED)/

Authorised officer of the Local Body

Name & Address of the Office / Department :

Public Health Engineering Department
Digboi Sub-Division.

To

PRINCIPAL,
OIL VALLEY SCHOOL
DIABOI, ASSAM.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf

Trilok K. Singh
 CHAIRMAN
 OIL VALLEY SCHOOL
 JLMT
 BOGAPANI, ASSAM

[Signature]
 PRINCIPAL
 OIL VALLEY SCHOOL
 JLMT
 BOGAPANI COLONY

GOVT. OF ASSAM
Sub-Divisional Level Laboratory, Digboi
PUBLIC HEALTH ENGINEERING DEPARTMENT
Digboi Sub-Division, Dist. Tinsukia, Assam; 786171
DRINKING WATER ANALYSIS REPORT


Test Report No. SDLL DIGBOI/LAB-JJM-1/2025-26/ **13, 13-05-2025**

1. Sample ID :SDLL/DIG/R/15
2. Issued To :AJIT HORE
3. Pin Point Location :OIL VALLEY SCHOOL
4. Gaon Panchayat :BOGAPANI
5. Village :BOGAPANI COLONY
6. Habitation :
7. Sample Collected by :AJIT HORE
8. Sample Quantity :500 MI
9. Date and Time of Collection :07/05/2025 : AM/PM
10. Date of Analysis :07/05/2025 / /2025
11. Date of Reporting :09/05/2025
12. Type of Source :BOREWELL (RAW)
13. Nature of Test : physical/chemical
14. Test Methods : As per BIS 10500:2012/2ND REVISION


PARTICULARS	Desirable Limit	Permissible Limit	Value	
PHYSICAL TESTS				
1. Colour	1	15	0	Hazen Units
2. Odour	Agreeable	Agreeable	Agreeable	
3. Taste	Agreeable	Agreeable		
4. Turbidity	1	5	3.2	NTU
CHEMICAL TESTS				
1. pH	6.5-8.5	No Relaxation	6.80	pH
2. Iron (Fe)	1	No Relaxation	0.833	mg/l
3. Alkalinity	200	600	70	mg/l
4. Chloride (Cl)	250	1000	26.942	mg/l
5. Residual Chlorine	0.2	1	0	mg/l
6. Hardness (CaCO ₃)	200	600	40	mg/l
7. Calcium (as Ca)	75	200		mg/l
8. Magnesium (as Mg)	30	100		mg/l
9. Total Dissolved Solids(TDS)	500	2000	62	mg/l
10. Sulphate (SO ₄)	200	400	0.450	mg/l
11. Flouride (F)	1	1.5	0.154	mg/l
12. Nitrate(NO ₃)	45	No Relaxation		mg/l
13. Arsenic (As)	0.01	No Relaxation		mg/l

Remarks:Given water sample is found to be safe as all tested parameters are within limits.


Note:1)The results given above are related to the sample as received and tested in this laboratory.
Reliability of sample lies with the sender.


Assistant Chemist
SDLL, Digboi Sub-Division
Digboi

Nodal Officer
SDLL, Digboi Sub-Division
Digboi


Asstt. Executive Engineer (PHE)
Digboi Sub-Division
Digboi

Tribal K. R. Gupta
CHAIRMAN
OIL VALLEY SCHOOL
JLMT
BOGAPANI, ASSAM


PRINCIPAL
OIL VALLEY SCHOOL
JLMT
BOGAPANI COLONY

GOVT. OF ASSAM
Sub-Divisional Level Laboratory, Digboi
PUBLIC HEALTH ENGINEERING DEPARTMENT
Digboi Sub-Division, Dist. Tinsukia, Assam; 786171
DRINKING WATER ANALYSIS REPORT

Test Report No. SDLL DIGBOI/LAB-JJM-1/2025-26/ 14, 13-05-2025

1. Sample ID :SDLL/DIG/R/16
2. Issued To :AJIT HORE
3. Pin Point Location :OIL VALLEY SCHOOL
4. Gaon Panchayat :BOGAPANI
5. Village :BOGAPANI COLONY
6. Habitation :
7. Sample Collected by :AJIT HORE
8. Sample Quantity :500 MI
9. Date and Time of Collection :07/05/2025 , : AM/PM
10. Date of Analysis :07/05/2025 - / /2025
11. Date of Reporting :09/05/2025
12. Type of Source :BOREWELL (FILTER)
13. Nature of Test : physical/chemical
14. Test Methods : As per BIS 10500:2012/2ND REVISION


PARTICULARS	Desirable Limit	Permissible Limit	Value	
PHYSICAL TESTS				
1. Colour	1	15	0	Hazen Units
2. Odour	Agreeable	Agreeable	Agreeable	
3. Taste	Agreeable	Agreeable		
4. Turbidity	1	5	1.9	NTU
CHEMICAL TESTS				
1. pH	6.5-8.5	No Relaxation	6.89	pH
2. Iron (Fe)	1	No Relaxation	0.529	mg/l
3. Alkalinity	200	600	74	mg/l
4. Chloride (Cl)	250	1000	26.942	mg/l
5. Residual Chlorine	0.2	1	0	mg/l
6. Hardness (CaCO ₃)	200	600	40	mg/l
7. Calcium (as Ca)	75	200		mg/l
8. Magnesium (as Mg)	30	100		mg/l
9. Total Dissolved Solids(TDS)	500	2000	50	mg/l
10. Sulphate (SO ₄)	200	400	0.361	mg/l
11. Flouride (F)	1	1.5	0.092	mg/l
12. Nitrate(NO ₃)	45	No Relaxation		mg/l
13. Arsenic (As)	0.01	No Relaxation		mg/l

Remarks:Given water sample is found to be safe as all tested parameters are within limits.

Note:1)The results given above are related to the sample as received and tested in this laboratory.
Reliability of sample lies with the sender.

Olson
Assistant Chemist
SDLL, Digboi Sub-Division
Digboi

Nodal Officer
SDLL, Digboi Sub-Division
Digboi


Asstt. Executive Engineer (PHE)
Digboi Sub-Division
Digboi

Tinku Kr Gupta
CHAIRMAN
OIL VALLEY SCHOOL
JLMT
BOGAPANI, ASSAM

Bony
PRINCIPAL
OIL VALLEY SCHOOL
JLMT
BOGAPANI COLONY